



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems

MTD-X Wedge Anchor
(see attached listing)

Prepared for:

Tecnicas Expansivas S.L.
P.I. La Portalada II
C\Segador 13
26006 Logroño
Spain

FM Approvals Class: 1952 (December 2016)

Approval Identification: PR453998 Approval Granted: October 1, 2019

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

| Product Designation | Hanger Rod Size, in | Component Description | For Nominal Pipe Sizes, in. | Remarks |
|---------------------|---------------------|-----------------------|-----------------------------|---------|
| MTD-X | 3/8 | Wedge Anchor | ¾ through 4 | a |
| MTD-X | 1/2 | Wedge Anchor | 5, 6, 8 | a |
| MTD-X | 5/8 | Wedge Anchor | 10, 12 | b |
| MTD-X | 3/4 | Wedge Anchor | 10, 12 | c |

Remarks:

- a. Minimum embedment 2.33 in.
- b. Minimum embedment 4.5 in.
- c. Minimum embedment 3.74in



Member of the FM Global Group